



- Note:
- 1) Top Air Intake standard. Front Intake optional.
 - 2) Frames must be assembled in the field. Hardware is provided.
 - 3) Consult factory for installation on standard lift OH doors.
 - 4) Factory set 5sec soft starter ramp up time.
 - 5) Controls: Lockable NEMA 1 Enclosure 640mm x 410mm x 215mm, with soft starter, 2 position keyed switch, external resets, 120V control circuit.
 - 6) 20 Gauge G.90 Galvanized metal cladding.
 - 7) Installation height not to exceed 1" above door jamb.
 - 8) Barrier is to be mounted on the buildings interior.
 - 9) Minimum clearance for air intake 10".
 - 10) 4 installation sliders provided.
 - 11) 2 Wall Mounts provided.
 - 12) Electrical connections and disconnect by others.

CSA & CMB CERTIFIED

ENERSHIELD INDUSTRIES LTD
16821-113 AVENUE
EDMONTON, ALBERTA T5M 2X2
 PH (780) 482-4662 FAX (780) 482-4074
 E-mail: info@enershield.ca
 www.enershield.ca

ENERSHIELD AIR BARRIER		Blowers	
VOLTAGE	FLA	Motor(s) TEFC, IP55, VFD Compatible, 1800 RPM	8
208/3/60	36.7 ea	2 @ 15hp	
460/3/60	18 ea	2 @ 15hp	
575/3/60	14.5 ea	2 @ 15hp	

Xtremeshield	XS-240
Air Velocity (fpm) (m/s)	7500/38.1
Air Volume (cfm) (l/s)	47,650 / 22,488
Total hp/watts	30 hp/22,380W
Weight lbs/Kg	1890 / 860

Project: _____
 Engineer: _____
 Tag: _____